

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0801:159 Page 1 of 1

CATEGORY: System Smoke Detectors/Photoelectric

LISTEE: Radionics, Div. Detection Systems Inc., 130 Perinton Pkwy, Fairport, NY 14450-9199
Contact: *James Gattelaro (716) 223-4060

DESIGN: Models D275 with Models MB200-2W and MB200-4W bases and EOL Model EOL-200. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with separately listed compatible control units.

XLf: 7272-1062:100

*Rev. 06-13-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 17, 2001**

Listing Expires **June 30, 2002**

Authorized By: **BEN HO**, Supervising Deputy
Program Manager